

000 4,750,330.4
4,575,377.-
176,953.*

REPORT

MAY 23 2008

962

INDUSTRIAL DEPARTMENT

MAY 23 2008

ADDRESS: 101 Columbia Rd, (Attn: Helen Fahy (NIC-3)) Morristown, NJ 07962

FACILITY LOCATION: 80 Kellogg St, Jersey City, NJ 07305

NEW CUSTOMER ID / OUTLET ID: 31630005-1

OLD OUTLET DESIGNATION

[illegible]

Start			End		
04	01	08	04	30	08
MO	DAY	YR	MO	DAY	YR

VOL DISCHARGE THIS PERIOD	
176,953	GALS
CU. FT X 7.48 = GALLONS	
EFFLUENT METER READING LAST DAY THIS PERIOD 4.750.830	


~~176.953~~ GALS

CU. FT X 7.48 - GALLONS

EFFLUENT METER READING LAST
DAY THIS PERIOD 4,750,830

[illegible][illegible]

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL OR AUTHORIZED AGENT	TYPE NAME AND TITLE	TELEPHONE NUMBER
	John J. Morris	(973) 455-4003
		DATE 5/29/08

Honeywell

Honeywell
P.O. Box 1057
Morristown, NJ 07962-1057

May 20, 2008

Andy Caltagirone
Manager of Industrial & Pollution Control
Passaic Valley Sewerage Commissioners
600 Wilson Ave
Newark, NJ 07105

RE: **Honeywell, Study Area 7**
Discharge of Tannin Construction Water
Customer ID# 31630005-1

Dear Mr. Caltagirone:

Honeywell is submitting the April 2008 discharge monitoring reports for the discharge of tannin construction water into the sanitary sewer at the 80 Kellogg St, Jersey City, Study Area 7 site. The enclosed MR1 and MR2 are in compliance with the permit limits.

Please contact me at 973-455-2989 if you need further clarification or have questions.

On Behalf of Honeywell
Sincerely



Helen Fahy
SA-7 Program Manager
Fahy Associates

Cc: File
Frank Schroyer

Honeywell International Inc., Study Area 7 (316300005-1) PVSC DAILY OPERATING LOG MONTH: April 2008																
DATE	OPERATOR	PREVIOUS TOT.	CURRENT TOT.	DAILY FLOW	MGD	pH	TOTAL CR	SGT-HEM	BOD5	CD	CU	PB	NI	HG	ZINC	CR LBS/DAY
				Permit Limit	0.2376	5-10.5		100 mg/l max		0.19 mg/l	3.02 mg/l	0.54 mg/l	5.9 mg/l	0.08 mg/l	1.67 mg/l	23 #/day
				gallons/day		pH Units	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	lbs/day
4/1/2008	Frank Schroyer	4579877	4584705	10,828	0.010828	7.23	15.60									1.41
4/2/2008	Frank Schroyer	4584705	4606583	21,878	0.021878	7.35	17.50									3.19
4/3/2008	Frank Schroyer	4606583	4606583	0	0	N.F.										0.00
4/4/2008	Frank Schroyer	4606583	4606583	0	0	N.F.										0.00
4/5/2008	Automode	4606583	4606583	0	0	N.F.										0.00
4/6/2008	Automode	4606583	4606583	0	0	N.F.										0.00
4/7/2008	Frank Schroyer	4606583	4606583	0	0	N.F.										0.00
4/8/2008	Frank Schroyer	4606583	4630503	23,920	0.02392	7.66	16.40									3.27
4/9/2008	Frank Schroyer	4630503	4667230	36,727	0.036727	10.08	7.12									2.18
4/10/2008	Frank Schroyer	4667230	4670424	3,194	0.003194	9.87	5.13									0.14
4/11/2008	Frank Schroyer	4670424	4670424	0	0	N.F.										0.00
4/12/2008	Automode	4670424	4681131	10,707	0.010707	8.84	14.70									1.31
4/13/2008	Automode	4681131	4691837	10,706	0.010706	8.84	14.70									1.31
4/14/2008	Frank Schroyer	4691837	4702544	10,707	0.010707	8.84	14.70	<5.1	49.8	<0.008	0.058	0.0082	0.152	0.00061	0.0638	1.31
4/15/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/16/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/17/1900	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/18/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/19/2008	Automode	4702544	4702544	0	0	N.F.										0.00
4/20/2008	Automode	4702544	4702544	0	0	N.F.										0.00
4/21/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/22/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/23/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/24/2008	Frank Schroyer	4702544	4702544	0	0	N.F.										0.00
4/25/2008	Frank Schroyer	4702544	4723075	20,531	0.020531	8.12	18.40									0.00
4/26/2008	Automode	4723075	4724194	1,119	0.001119	8.43	17.00									3.15
4/27/2008	Automode	4724194	4725312	1,118	0.001118	8.43	17.00									0.16
4/28/2008	Frank Schroyer	4725312	4726431	1,119	0.001119	8.43	17.00									0.16
4/29/2008	Frank Schroyer	4726431	4726431	0	0	N.F.										0.00
4/30/2008	Frank Schroyer	4726431	4750830	24,399	0.024399	7.02	18.10									3.68
TOTAL				176,953	0.176953			<5.1	49.8	<0.008	0.058	0.0082	0.152	0.00061	0.0638	
				High:											High:	
				Average:											Average:	

Note: N.F. means no flow for the day.